Handling-Short Instruction for USB-RS232-Converter-Cable 9359-1-RS232 V1.0



The USB-Serial-Converter-Cable is an interface cable for the 9pin PC-Port. The cable should be connected to the USB-Port (type A-connector).

 In the case of the Cable are 2 LED's embedded:

 GREEN
 lights when data is transferred to the PLC

 YELLOW
 lights when data is transferred from PLC to PC

Install the cable

First connect the USB-Serial-Converter-Cable into a free USB-Port of your computer. Please download from the below listed web-side the USB-driver for the USB-Serial-Converter-Cable.

Extract the file on your PC and guide the starting hardware-installation-wizard to this folder. The software will install the drivers for the USB-Serial-Converter-Cable automatically.

After the driver is installed successfully the COM port is displayed in Control Panel \rightarrow System \rightarrow Device manager \rightarrow COM and LPT \rightarrow Properties (Right mouse click) \rightarrow Extended.

If you changed the COM-Port-Number, restart the PC to activate this COM-Port. After restart choose in the application the selected COM-Port in the configuration.

Using the original Siemens S5 software in a DOS window

Do you use the original Siemens S5 patch once. You can download this named web-side and install it on that PC. Go on with choosing the language. "OK". Press "Install" and choose the installed. The installation routine is now have to select the used COM port. Then "End" as soon as the installation is

Attention: For the Step5-Original COM4 selected. If necessary change the select "System". In the Tab "Hardware", Device-Manager the virtual COM-Port is and LPT)", Right click "USB Serial Port "Properties". In the following dialog

Device-Select		
	Wich Device did you use ?	
Device	PG-USB	
	C S5-LAN	
	O USB-Serial	
	 PLCVCOM-Multi WinTeleProf 	
	OK	



software, then you need to run the S5-"Step5 additional driver" also from the

Select "USB-Serial" and confirm with folder where the S5 software is searching for the S5 software. Next you the S5 patch will be installed. Press completed.

application there **must** be one COM1 to COM port. Go to the Control Center, click button "Device manager". In the listed in the section "Interfaces (COM (COMx)", in the Context Menu choose select the tab "Port Settings". Click onto

the button "Advanced", in the next dialog you could choose the COM-Port.

Using S5 Original-Software under Windows 98

A virtual created COM port cannot be used directly from a MSDOS Box (Windows 98). The solution is easy just

Advanced Settings for COMI			<u></u>	×
DDN Port Number: DDN 4 USB Transfer Sizes Select lower settings to correct p Select higher settings for foster p Receive (Bytes)	4296	v baud rates.	OK Cancel Defaultz	I
Transmit (Bytes):	4096			
BM Options				
Select lower settings to correct te	sponse problems.			
Latency Timer (scec)	16 💌			
Niscellaneous Options				
Ninimum Read Timeout (meec) Ninimum Wile Timeout (meec)	1000 ×	Seial Enumenator Seial Printer Cancel II Power Oti Event On Surprise Removal Set RTS On Close		

install the "S5 VCOM for Win98". In the PG-USB menu expand the tree and select the entry "S5 VCOM for Win98". Choose the language and enter the path where the software should be installed. Select the name for the start menu and click next to proceed with the installation. After the End of the Installation the PC must be rebootet. S5 VCOM is installed into the Autostart-Directory and is started every time the PC boots. If an error occurs while installation or starting of driver, a message is shown. If correctly installed, on the bottom-right corner of the Screen a new tray icon is displayed.

the software should be installed. Select the name for the start menu and click next to proceed with the installation. After the End of the Installation the PC must be rebootet. S5 VCOM is installed into the Autostart-Directory and is started every time the PC boots. If an error occurs while installation or starting of driver, a message is shown. If correctly installed, on the bottom-right corner of the Screen a new tray icon is displayed.

This Tray-Icon shows, if a USB-Serialand if a communication is in progress.(S=from

If you double-click displayed:

In the section State is for communication

In the section virtual on the left side is the Windows-Software

S5-VCom			
Status			
S5-LAN	Kein Netzwerk IP	ungültig	konfiguriere
PG USB	nicht verbunden		
virtueller Port			
COM4	<.>>	COM3 (03E8 IF	0.41

Converter-Cable is connected or not, PC to S5,E=from S5 zu PC)

on the Tray-Icon a new Dialog is

displayed which Interface-Cable is used and if a connection exists.

Port the following information is shown COM - Port which is used from and on the right side the COM-Port (IO-

Ports) of the MS-DOS Box. This COM-Port should be selected in the S5-Software. According which COM - Ports already exists, the next free COM-Port will be used:

existing COM NONE COM1 COM1,COM2 COM1,COM3 COM1,COM2,COM3
 from S5VCOM used

 COM1 [03F8h,IRQ4]

 COM2 [02F8h,IRQ3]

 COM3 [03E8h,IRQ4]

 COM2 [02F8h,IRQ3]

 COM4 [02E8h,IRQ3]

In the section Program you could exit the application, change the language of the application or minimize to the tray-icon.

PG 95 / PG 2000

Select under Options \rightarrow Interface the corresponding virtual COM-Port.

S5 for Windows

In Files → Poperties → Interface select the Protocol "S5" and the virtual COM-Port

More information to Interface-Cables, also the actual handbooks online under

Under the web-address https://www.process-informatik.de are product specific documentations or software-driver/-tools available to download. If you have questions or suggestions about the product, please don't hesitate to contact us.

Process-Informatik Entwicklungsgesellschaft mbH Im Gewerbegebiet 1 DE-73116 Wäschenbeuren +49 (0) 7172-92666-0

> info@process-informatik.de https://www.process-informatik.de

Copyright by PI 2006 - 2024

Menutree Website:

- + Products / docu / downloads
 - + Hardware
 - + Converter
 - + USB-serial-converter cable








Please make sure to update your drivers before using our products.

Variable-chart without Step7-programming package



You would like to give your customer the opportunity to read current numbers of the manufacturing Online, without installing a visualisation or even the STEP7-package? Then a S7-LAN with the option Status Variable" is needed, and your customer can take a look at these password protected data on a site of the integrated webserver.



Move wirelessly around the machine with LAN-port and communicate for example ONLINE in the status

Remote-maintenance Siemens-S5-PLC



Remote-maintenance of a Siemens-S5-controller with S5-LAN++ on PD-port via secure VPN-tunnel of the TeleRouter