


Handling-short-instruction V1.0 for

L1-BUS Controller



Power connection:

Voltage: 24 V DC \pm 20% (Desktop-Device)
 5 V DC \pm 20% (DIN-Rail-Mounting)
 Power: 4W

Initial start-up :

- Plug the needed modules into the right connectors. The components on the module-board point in your direction
- Connect the L1-Bus to the 9pin connector with screws
- Connect the PC to the D-Sub 9pin
- Check Dip-Switch described like in the handbook (default setting: 9600bd, 8, N, 1)
- Connect power-supply:
 Desktop-Device: 24V DC to the 2pin connector with screws (Pin1 GND, Pin2 Vcc)
 Din-Rail-Device: 5V DC to the 3pin connector with screws (Pin1 Vcc, Pin2 GND)

Now you will be able to communicate with a PC over RS232 with the controller. More informations you can find in the handbook of the device.

Under the web-address <https://www.process-informatik.de> are product specific documentations or software-driver/-tools available to download.
If you have questions or suggestions about the product, please don't hesitate to contact us.

Process-Informatik Entwicklungsgesellschaft mbH

Im Gewerbegebiet 1

DE-73116 Wäschenbeuren

+49 (0) 7172-92666-0

info@process-informatik.de

<https://www.process-informatik.de>

Copyright by PI - 2025

Menutree Website:

- + Products / docu / downloads
- + Hardware
 - + Converter
 - + L1-Controller




QR-Code Website:




Please make sure to update your drivers before using our products.

Data acquisition/logging




By connecting a line-recorder to the EtherSens-device anyone without network-knowledge can visually capture and further process the log.

Remote maintenance of a S7-PLC[FREWARE without support]




You have to solve a problem in the PLC-program, but the installation is not placed nearby? No problem, start your PG-2000-software with "option teleservice", activate your modem and after selection intra PG-2000-software access to the PLC is possible as if being on-site.

Data backup S7-PLC PN-port on USB-stick



S7-PLC triggered DB-backup/-restore without additional PC via PN-port to USB-stick

Wireless around the Beckhoff-PLC



Move wirelessly around the Beckhoff-PLC and communicate for example ONLINE in the status