
Using S7-LAN with an ALF as a WLAN Router




1 Connect the 24V power source and the computer to configure



2 Select "AP-Router" on menu "Easy Setup"




Configure your IP address and subnet mask



Now configure your networkname and encryption

Our recommended encryption is WPA2



Connect the S7-LAN with a patch cable
Your S7-LAN is now available from every WLAN participants




6 Installing TIC driver
TIC driver avaiable on
www.tpa-partner.de


Integrate a S7-LAN in a avaiable WLAN with an ALF




1 Connect the 24V power source and the computer to configure



2 Select "Client Bridge" on menu "Easy Setup"



Press "Site Survey" to search every WLAN and select your WLAN



4 Select your WLAN and enter your passwort. Press "Done" to confirm



Connect the S7-LAN with a patch cable
 Every network has to be in the same IP area
 Your Module is now integrated




6 Installing TIC driver
TIC driver avaiable on
www.tpa-partner.de


Integrate a S5-LAN++ in a avaiable WLAN with an ALF




1 Connect the 24V power source and the computer to configure



2 Select "Client Bridge" on menu "Easy Setup"



Press "Site Survey" to search every WLAN and select your WLAN



Select your WLAN and enter your passwort. Press "Done" to confirm



Connect the S5-LAN++ with a patch cable Every network has to be in the same IP area Your Module is now integrated




Installation:
- S5-Patch for original Step5
- PLCVCOM (virtual COM-Port)
Tools available on
www.tpa-partner.de

Using S5-LAN++ with an ALF as a WLAN Router



1 Connect the 24V power source and the computer to configure



2 Select "AP-Router" on menu "Easy Setup"



Configure your IP address and subnet mask



Now configure your networkname and encryption

Our recommended encryption is WPA2



Connect the S5-LAN++ with a patch cable Your S5-LAN++ will get an IP from the DHCP server and is now available from every WLAN participants



Installation:
- S5-Patch for original Step5
- PLCVCOM (virtual COM-Port)
Tools available on
www.tpa-partner.de

Under the web-address https://www.process-informatik.de are product specific documentations or software-driver/-tools available to download.

If you have questions or suggestions about the product, please don't hesitate to contact us.

Process-Informatik Entwicklungsgesellschaft mbH Im Gewerbegebiet 1 DE-73116 Wäschenbeuren +49 (0) 7172-92666-0

info@process-informatik.de https://www.process-informatik.de

Copyright by PI - 2025

Menutree Website:

QR-Code Website:

- + Products / docu / downloads
 - + Hardware
 - + Programming devices
 - + Programming adapter S7
 - + WLAN/WIFI
 - + Profinet PLCs / Ethernet-CPs
 - + ALF-Devices
 - + ALF








Please make sure to update your drivers before using our products.

Data backup S5-PLC on USB-stick via dig. IO




Via digital input triggered DB-backup/-restore without additional PC via PG-socket and Ethernet to USB-stick

Data backup S7-PLC over MPI/Profibus on USB-stick via dig. IO



Via digital input triggered DB-backup/-restore without additional PC via MPI/Profibus to USB-stick

Router - Mode (access to the network without router)



The Tele-Prof-II can also be used as a router for access from a PC via dial-up connection, so that a communication with the behind covered network results. Furthermore a network connection can be made with the TP-II TP-II-line, but in doing so the IP-address-root must differ.

Easiest configuration by included webserver




To configure ALF you dont need additional driver or special cables, you connect your PC via LAN or WLAN with ALF and over the integrated webserver you can configure the needed function.

Data backup S5-PLC on FTP-Server



S5-PLC triggered DB-backup/-restore without additional PC via PG-socket and Ethernet on FTP-server

Communication-driver for S5-PLC



S5-PLCs and you need data in your PC or production planning system?

The S5-communication-drivers connect the office-world with the control-world. Be it classic with a serial-port of the PC up to communication over the network. Thanks to additional adapters (such as S5-LAN++), controllers without a LAN connection can be connected to the network. Nothing stands in the way of communication with an IP-address. On your PC for Windows as a DLL-file, for Linux as an object, you have tools where you can access the data of the controls by calling up functions such as "ReadBlock" or "WriteFlag". Tie for e.g. the DLL into your project and your application already has PLC-access or simply access the data with Excel and process it in Excel.