


Technical data / connection
Magnetic base antenna for indoor use

Specification

Frequency range	2400 MHz – 2500 MHz
Gain	9.3 dBi
VSWR	≤ 1.6:1 Max.
Polarization	Linear, vertical
Impedance	50 Ω
Connector	R/P SMA PLUG

Environmental & Mechanical Characteristics

Temperature	-10°C to +55°C
Humidity	95% @55°C



Connection:

Place the antenna base on a metal surface and screw on the rod. Screw with feeling the cable on the device onto the WIFI socket.

Under the web-address <https://www.process-informatik.de> are product specific documentations or software-driver/-tools available to download.
If you have questions or suggestions about the product, please don't hesitate to contact us.

Process-Informatik Entwicklungsgesellschaft mbH

Im Gewerbegebiet 1

DE-73116 Wäschenbeuren

+49 (0) 7172-92666-0

info@process-informatik.de

<https://www.process-informatik.de>

Copyright by PI - 2025

Menutree Website:

+ Products / docu / downloads

+ Accessories

+ Antennas / Accessories


+ Magnetic base antenna for S5-/S7-BRIDGE / CONNECT

QR-Code Website:




Please make sure to update your drivers before using our products.

Data backup S7-PLC over MPI/Profibus on FTP-server



S7-PLC triggered DB-backup/-restore without additional PC via MPI/Profibus on FTP-server

Turbo-LAN-interface for the S5




S5-115U/135U/150U/155U and need further processing of data via network and PG interface too slow?

Plug the "S5-TCPIP 100" interface-card into a free slot in the rack, integrate the card into the S5 and nothing stands in the way of communication. Access the controller-data "parallel" to the PG-interface with "Power", regardless of whether it is "TCP/IP" or "ISO on TCP (RFC1006)", "ISO (H1)", "Modbus on TCP" or "SPS header", the interface-card reacts to the various protocols according to your configuration and returns the required data.


With the integrated 4-way-switch, several LAN-participants can be connected to the card and thus to the controller.

E-Mail notification



Do you monitor processes and upon reaching a predetermined upper/lower limit, you need a message? Then activate in the device the limit-value-monitoring and you get this message. Furthermore, the device also sends its state and you are always up to date.

Data backup S7-PLC over MPI/Profibus on SD-card via dig. IO



Via digital input triggered DB-backup/-restore without additional PC via MPI/Profibus to SD-card